



GEMİ ANEMOSTADLARI Seçim Tablosu

O: Açıklık O: Opening	GA 90	Hava debisi				Air flow (m³/h)		
			50	60	80	100	150	200
5 mm	Pt de	(Pa) (dB)	105 33	150 38	240 47	350 53		
	10 mm	Pt de	(Pa) (dB)	45 23	60 29	100 37	140 44	260 55
	15 mm	Pt de	(Pa) (dB)		35 22	55 30	80 38	160 48
	20 mm	Pt de	(Pa) (dB)		22 -	35 25	50 31	105 45

O: Açıklık O: Opening	GA 90	Hava debisi				Air flow (m³/h)		
			50	60	80	100	150	200
5 mm	Pt de	(Pa) (dB)	80 34	115 38	180 43			
	10 mm	Pt de	(Pa) (dB)		40 29	70 35	100 40	180 43
	15 mm	Pt de	(Pa) (dB)		30 25	48 31	68 35	125 44
	20 mm	Pt de	(Pa) (dB)			32 26	45 31	85 38

O: Açıklık O: Opening	GA 90	Hava debisi				Air flow (m³/h)		
			60	80	100	150	200	300
7 mm	Pt de	(Pa) (dB)	36 20	60 28	95 35	215 45		
	11 mm	Pt de	(Pa) (dB)	20 -	35 21	523 27	115 37	200 45
	14 mm	Pt De	(Pa) (dB)			29 20	60 27	105 37